

50.1


EQC - NOV and Order

Shoshone Lodge


DEQ Docket No. 3812-05

EQC Docket No. 05-3223





**State Archives
Scanned as
Received**



**The Following
Document(s) May Be
Illegible In Part Or
Entirely.**

CASE INFORMATION SHEET

NOV and C&D

Name H. KEITH DAHLEM
SHOSHONE LODGE

Docket/Permit No. 05-

Permit No. _____

TFN No. _____

Address P.O. BOX 195
CODY, WY 82414

Division WATER

Date of Request of Hearing _____

Date NOV/CD issued 10-27-05

Place of Hearing _____

Hearing Examiner: _____

Council Members Present at the Hearing: _____

Date _____

Time _____

Reporter _____

Date Continued _____

Date Dismissed _____

Date Withdrawn _____

Reasons _____

Others Present _____

Attorneys for Parties:

Name: _____

Tel. No. _____

Fax No. _____

Name: _____

Tel No. _____

Fax No. _____

Attorney for Division :

MIKE BARRASH

Type of Case:

NOV & CD

Date of Notice of Hearing and Order _____

Due Date for Prehearing Memos _____

Due Date for Findings, Conclusions, & Briefs _____

Responsible for Draft Copy _____

Decision _____

Notes

Located @ 349 Yellowstone Hwy., Cody, WY

Two active above ground storage tanks, each, 1000
gallon steel tanks containing gasoline.

Failed to pay above ground storage tank fee (\$100.00)

FILED

**BEFORE THE
ENVIRONMENTAL QUALITY COUNCIL
STATE OF WYOMING
EQC DOCKET NO. 05-3223**

FEB 17 2006

Terri A. Lorenzon, Director
Environmental Quality Council

IN THE MATTER OF THE NOTICE OF)
VIOLATION AND ORDER ISSUED TO:)

H. Keith Dahlem)

Shoshone Lodge)

P.O. Box 195)

Cody, WY 82414)

DEQ DOCKET NO. 3812-05)

ORDER APPROVING
ORDER

The above-referenced matter having been considered by the Environmental Quality Council pursuant to the provisions of W.S. 35-11-112(a)(ii), and it appearing to the Council that the time has expired for the filing of an appeal before this body from this order of the Department of Environmental Quality entered herein, and the Council being fully advised in the premises;

IT IS HEREBY ORDERED THAT the order of the Department of Environmental Quality entered herein be and the same hereby is approved.

DATED this 15th day of February, 2006.



Mark Gordon, Chairman
Environmental Quality Council
Room 1714, Herschler Building, 1st Floor West
122 W. 25th Street
Cheyenne, WY 82002
Phone: 307-777-7170
Fax: 307-777-6134

CERTIFICATE OF SERVICE

I, Kim McGee, certify that at Cheyenne, Wyoming, on the 17th day of February, 2006, I served a copy of the foregoing ORDER APPROVING ORDER by depositing copies of the same in the United States mail, postage prepaid, duly enveloped and addressed to:


H. Keith Dahlem
Shoshone Lodge
P.O. Box 195
Cody, WY 82414

also to the following persons via interoffice mail:

John Corra, Director
Department of Environmental Quality
Herschler Building, 4th West
Cheyenne, WY 82002

John Wagner, Administrator
Water Quality Division
Department of Environmental Quality
Herschler Building, 4th West
Cheyenne, WY 82002

Mike Barrash
Senior Assistant Attorney General
Attorney General's Office
123 Capitol Building
Cheyenne, WY 82002



Kim McGee, Executive Assistant
Environmental Quality Council

OCT 27 2005

Terri A. Lorenzon, Director
Environmental Quality CouncilBEFORE THE
ENVIRONMENTAL QUALITY COUNCILSTATE OF WYOMINGIN THE MATTER OF THE NOTICE OF
VIOLATION AND ORDER ISSUED TO:H. Keith Dahlem
Shoshone Lodge
P. O. Box 195
Cody, WY 82414

DOCKET NUMBER 3812-05

NOTICE OF VIOLATIONANDORDER

NOTICE IS HEREBY GIVEN THAT:

1. Facility number 0-001952 is located at 349 Yellowstone Highway, Cody, Wyoming. There are two active above ground storage tanks on this facility, both 1,000 gallon steel tanks containing gasoline. On May 11, 2005, Shoshone Lodge (owned by H. Keith Dahlem) was invoiced for above ground storage tank fees and provided with an annual registration form filled out for the facility. On August 24, 2005 and September 27, 2005, Shoshone Lodge was again invoiced for above ground storage tank fees. The responsibility for above ground storage tank fees rests with either the owner or the operator. Shoshone Lodge is registered as both the owner and the operator. Above ground storage tank fees have not been paid for fiscal year 2006. Presently One Hundred Dollars (\$100.00) remains unpaid, and the fiscal year 2006 registration has not been submitted;

2. Shoshone Lodge has failed to pay above ground storage tank fees which are mandatory under W.S. 35-11-1425, and has failed to register the tanks as required by W.S. 35-11-1419 and Chapter 17, Section 7(b), Wyoming Water Quality Rules and Regulations;

3. Since the above ground storage tank fees have not been paid for fiscal year 2006 and those fees were due July 1, 2005, Shoshone Lodge/H. Keith Dahlem, is required to provide financial responsibility under Chapter 19, Wyoming Water Quality Rules and Regulations;

4. W.S. 35-11-1419 states: "On or before July 1 of each year the owner or operator of a tank shall register the tank with the department on forms developed and furnished by the department."

W.S. 35-11-1425 states: "On or before July 1 of each year either the owner or operator of a tank shall pay a fee to the department of two hundred dollars (\$200.00) per tank owned or operated, except that the owner or operator of an aboveground storage tank subject to this section that holds five thousand (5,000) gallons or less shall pay a fee of fifty dollars (\$50.00) per tank owned or operated. This fee shall be deposited in the corrective action account."

Wyoming Water Quality Rules and Regulations, Chapter 17, Section 7(b), states: "On or before July 1 of each year either the owner and/or operator of an above ground storage tank system shall register the system with the department on forms developed and furnished by the department. The registration form shall be submitted under oath or affirmation."

Wyoming Water Quality Rules and Regulations, Chapter 17, Section 7(e)(iii), states: "(e) All owners and/or operators of new above ground storage tank systems must certify on the notification or certification of compliance form conformance with the following requirements: (iii) Financial responsibility under Chapter 19, Water Quality Rules and Regulations, Above ground Storage Tank Program Financial Responsibility."

5. By failing to pay above ground storage tank fees for facility 0-001952, Shoshone Lodge, has violated W.S. 35-11-1425. By failing to register the tanks on facility 0-001952, Shoshone Lodge has violated W.S. 35-11-1419 and Chapter 17, Section 7(b), Wyoming Water Quality Rules and Regulations. By failing to provide financial responsibility for facility 0-001952, Shoshone Lodge has violated Chapter 17, Section 7(e)(iii), and Chapter 19, Wyoming Water Quality Rules and Regulations;

6. This Notice is being sent to you pursuant to W.S. 35-11-701(c)(i), which requires that in any case of the failure to correct or remedy an alleged violation, the director of the Department of Environmental Quality shall cause a written notice to be issued and served upon the person alleged to be responsible.

ORDER

BEFORE THE ENVIRONMENTAL QUALITY COUNCIL-STATE OF WYOMING

WHEREFORE IT IS HEREBY ORDERED THAT SHOSHONE LODGE SHALL:

1. Within thirty (30) days of the receipt of this notice, pay all above ground storage tank fees for facility 0-001952. The above ground storage tank fees for this site total One Hundred Dollars (\$100.00);

2. Within thirty (30) days of the receipt of this notice, file the registration form for the above ground storage tanks at facility 0-001952 as required by W.S. 35-11-1419;

3. If items 1 and 2 are complied with, this will constitute full compliance with this Administrative Order. The remaining items on this Order shall be complied with if items 1, 2 and 3 are not complied with within thirty (30) days:

OR

4. Within thirty (30) days of the receipt of this notice, place the tanks at facility 0-001952 in temporarily out of use condition and empty the tanks within one inch of the bottom. The tanks shall be registered with the department at that time as "temporarily out of service" tanks. Disconnect all above ground piping from the tanks until such time as they can be placed back in service;


5. Enter into a written agreement with the department as to when the above ground storage tank fees will be paid;

6. If these tanks have not been placed back in service within one (1) year of the date when they were placed in temporarily out of use condition, then Shoshone Lodge shall, at its own expense remove the tanks, decommission them in a licensed facility, and notify the department in advance so that a department inspector can witness the removal.


THIS ORDER is final unless, not later than ten (10) days after the date this notice is received, it is appealed by filing two written petitions for a hearing before the Environmental Quality Council. If a hearing is requested, the first petition shall be mailed to the Chairman, Wyoming Environmental Quality Council, Room 1714 Herschler Building, 1st Floor West, 122 West 25th Street, Cheyenne, Wyoming 82002. The second petition shall be mailed to the Director, Wyoming Department of Environmental Quality, Herschler Building, 4th Floor West, 122 West 25th Street, Cheyenne, Wyoming 82002. Both petitions must be sent by certified mail, return receipt requested.

NOTHING IN THIS ORDER shall be interpreted to in any way limit or contravene any other remedy available under the Environmental Quality Act, nor shall this Order be interpreted as being a condition precedent to any other enforcement action.

ORDERED this 24th day of October, 2005.


John V. Corra
Director

Department of Environmental Quality


John F. Wagner
Administrator

Water Quality Division

PLEASE DIRECT ALL INQUIRES TO: Robert Lucht, P.E. & P.G. Storage Tank Program Principal at 122 West 25th Street, Fourth Floor, West Wing, Cheyenne, WY 82002, (307) 777-7095 or (307) 777-5973 FAX for technical matters.

JVC/JFW/RFL/bb/5-1151.ltr

OCT 27 2005

**Terri A. Lorenzon, Director
Environmental Quality Council**

BEFORE THE
ENVIRONMENTAL QUALITY COUNCIL

STATE OF WYOMING

IN THE MATTER OF THE NOTICE OF)
VIOLATION AND ORDER ISSUED TO:)

H. Keith Dahlem)
Shoshone Lodge)
P. O. Box 195)
Cody, WY 82414)

DOCKET NUMBER 3812-05

NOTICE OF VIOLATION

AND

ORDER

NOTICE IS HEREBY GIVEN THAT:

1. Facility number 0-001952 is located at 349 Yellowstone Highway, Cody, Wyoming. There are two active above ground storage tanks on this facility, both 1,000 gallon steel tanks containing gasoline. On May 11, 2005, Shoshone Lodge (owned by H. Keith Dahlem) was invoiced for above ground storage tank fees and provided with an annual registration form filled out for the facility. On August 24, 2005 and September 27, 2005, Shoshone Lodge was again invoiced for above ground storage tank fees. The responsibility for above ground storage tank fees rests with either the owner or the operator. Shoshone Lodge is registered as both the owner and the operator. Above ground storage tank fees have not been paid for fiscal year 2006. Presently One Hundred Dollars (\$100.00) remains unpaid, and the fiscal year 2006 registration has not been submitted;

2. Shoshone Lodge has failed to pay above ground storage tank fees which are mandatory under W.S. 35-11-1425, and has failed to register the tanks as required by W.S. 35-11-1419 and Chapter 17, Section 7(b), Wyoming Water Quality Rules and Regulations;

3. Since the above ground storage tank fees have not been paid for fiscal year 2006 and those fees were due July 1, 2005, Shoshone Lodge/H. Keith Dahlem, is required to provide financial responsibility under Chapter 19, Wyoming Water Quality Rules and Regulations;

4. W.S. 35-11-1419 states: "On or before July 1 of each year the owner or operator of a tank shall register the tank with the department on forms developed and furnished by the department."

W.S. 35-11-1425 states: "On or before July 1 of each year either the owner or operator of a tank shall pay a fee to the department of two hundred dollars (\$200.00) per tank owned or operated, except that the owner or operator of an aboveground storage tank subject to this section that holds five thousand (5,000) gallons or less shall pay a fee of fifty dollars (\$50.00) per tank owned or operated. This fee shall be deposited in the corrective action account."

Wyoming Water Quality Rules and Regulations, Chapter 17, Section 7(b), states: "On or before July 1 of each year either the owner and/or operator of an above ground storage tank system shall register the system with the department on forms developed and furnished by the department. The registration form shall be submitted under oath or affirmation."

Wyoming Water Quality Rules and Regulations, Chapter 17, Section 7(e)(iii), states: "(e) All owners and/or operators of new above ground storage tank systems must certify on the notification or certification of compliance form conformance with the following requirements: (iii) Financial responsibility under Chapter 19, Water Quality Rules and Regulations, Above ground Storage Tank Program Financial Responsibility."

5. By failing to pay above ground storage tank fees for facility 0-001952, Shoshone Lodge, has violated W.S. 35-11-1425. By failing to register the tanks on facility 0-001952, Shoshone Lodge has violated W.S. 35-11-1419 and Chapter 17, Section 7(b), Wyoming Water Quality Rules and Regulations. By failing to provide financial responsibility for facility 0-001952, Shoshone Lodge has violated Chapter 17, Section 7(e)(iii), and Chapter 19, Wyoming Water Quality Rules and Regulations;

6. This Notice is being sent to you pursuant to W.S. 35-11-701(c)(i), which requires that in any case of the failure to correct or remedy an alleged violation, the director of the Department of Environmental Quality shall cause a written notice to be issued and served upon the person alleged to be responsible.

ORDER

BEFORE THE ENVIRONMENTAL QUALITY COUNCIL-STATE OF WYOMING

WHEREFORE IT IS HEREBY ORDERED THAT SHOSHONE LODGE SHALL:

1. Within thirty (30) days of the receipt of this notice, pay all above ground storage tank fees for facility 0-001952. The above ground storage tank fees for this site total One Hundred Dollars (\$100.00);
2. Within thirty (30) days of the receipt of this notice, file the registration form for the above ground storage tanks at facility 0-001952 as required by W.S. 35-11-1419;
3. If items 1 and 2 are complied with, this will constitute full compliance with this Administrative Order. The remaining items on this Order shall be complied with if items 1, 2 and 3 are not complied with within thirty (30) days:

OR

4. Within thirty (30) days of the receipt of this notice, place the tanks at facility 0-001952 in temporarily out of use condition and empty the tanks within one inch of the bottom. The tanks shall be registered with the department at that time as "temporarily out of service" tanks. Disconnect all above ground piping from the tanks until such time as they can be placed back in service;


5. Enter into a written agreement with the department as to when the above ground storage tank fees will be paid;


6. If these tanks have not been placed back in service within one (1) year of the date when they were placed in temporarily out of use condition, then Shoshone Lodge shall, at its own expense remove the tanks, decommission them in a licensed facility, and notify the department in advance so that a department inspector can witness the removal.

THIS ORDER is final unless, not later than ten (10) days after the date this notice is received, it is appealed by filing two written petitions for a hearing before the Environmental Quality Council. If a hearing is requested, the first petition shall be mailed to the Chairman, Wyoming Environmental Quality Council, Room 1714 Herschler Building, 1st Floor West, 122 West 25th Street, Cheyenne, Wyoming 82002. The second petition shall be mailed to the Director, Wyoming Department of Environmental Quality, Herschler Building, 4th Floor West, 122 West 25th Street, Cheyenne, Wyoming 82002. Both petitions must be sent by certified mail, return receipt requested.

NOTHING IN THIS ORDER shall be interpreted to in any way limit or contravene any other remedy available under the Environmental Quality Act, nor shall this Order be interpreted as being a condition precedent to any other enforcement action.

ORDERED this 24th day of October, 2005.


John V. Corra
Director
Department of Environmental Quality


John F. Wagner
Administrator
Water Quality Division

PLEASE DIRECT ALL INQUIRES TO: Robert Lucht, P.E. & P.G. Storage Tank Program Principal at 122 West 25th Street, Fourth Floor, West Wing, Cheyenne, WY 82002, (307) 777-7095 or (307) 777-5973 FAX for technical matters.

JVC/JFW/RFL/bb/5-1151.ltr